

4.13.4 Performance Evaluation Methodologies for PDRs and RDRRs

4.13.4.1 Customer Load Baseline Methodology

For each Proxy Demand Resource or Reliability Demand Response Resource, the CAISO will calculate the Customer Load Baseline as follows:

- (a) The CAISO will collect Meter Data for the Proxy Demand Resource or Reliability Demand Response Resource for calendar days preceding the Trading Day on which the Demand Response Event occurred for which the CAISO is calculating the Customer Load Baseline. Where the Proxy Demand Resource or Reliability Demand Response Resource uses behind-the-meter generation to offset Demand, the Proxy Demand Resource or Reliability Demand Response Resource may elect to provide, at all times, Meter Data reflecting the total gross consumption, independent of any offsetting Energy produced by behind-the-meter generation. To determine the calendar days for which the Meter Data will be collected, the CAISO will work sequentially backwards from the Trading Day under examination up to a maximum of forty-five (45) calendar days prior to the Trading Day, including only Business Days if the Trading Day is a Business Day, including only non-Business Days if the Trading Day is a non-Business Day, and excluding calendar days on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services, except as discussed below. The CAISO will stop collecting Meter Data for this purpose if and when it is able to collect Meter Data for its target number of calendar days, which target number is ten (10) calendar days if the Trading Day is a Business Day or four (4) calendar days if the Trading Day is a non-Business Day. If the CAISO is unable to collect Meter Data for its target number of calendar days, it will attempt to collect Meter Data for a minimum of five (5) calendar days if the Trading Day is a Business Day or a minimum of four (4) calendar days if the Trading Day is a non-Business Day. If the CAISO is unable to collect Meter Data for the minimum number of calendar days described above, the CAISO will instead collect

Meter Data for the calendar days on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services, and for which the amount of totalized load was highest during the hours when the Demand Response Services were provided in the forty-five (45) calendar days prior to the Trading Day.

- (b) The CAISO will calculate the simple hourly average of the collected Meter Data to determine a baseline amount of Energy provided by the Proxy Demand Resource or Reliability Demand Response Resource.
- (c) Unless otherwise requested by the Demand Response Provider and approved by the CAISO, the CAISO will multiply the amount calculated pursuant to Section 4.13.4.1(b) by a percentage equal to the ratio of (i) the average load of the Proxy Demand Resource or Reliability Demand Response Resource during the second, third, and fourth hours preceding the hour of the Trading Day on which the Proxy Demand Resource or Reliability Demand Response Resource provided the Demand Response Services during the Demand Response Event to (ii) the average load of the Proxy Demand Resource or Reliability Demand Response Resource during the same second, third, and fourth hours of the calendar days for which the CAISO has collected Meter Data pursuant to Section 4.13.4.1(a). The percentage can have a maximum value of one hundred-twenty (120) percent and a minimum value of eighty (80) percent.
- (d) If the Proxy Demand Resource or Reliability Demand Response Resource elects to provide Meter Data reflecting the total gross Demand at all times, independent of any offsetting Energy, the offsetting Energy must be metered separately from Load to enable the accurate calculation of total gross consumption.

4.13.4.2 Metering Generator Output Methodology

For behind-the-meter generation registered in Proxy Demand Resources or Reliability Demand Response Resources and settling Energy Transactions pursuant to Section 11.6.2, the Generator Output Baseline will be calculated as follows:

- (a) Meter Data will be collected for the behind-the-meter generation for the same hour as the Trading Hour on calendar days preceding the Trading Day on which the Demand Response Event occurred for which the Generator Output Baseline is calculated. Meter Data will consist of Energy output of the behind-the-meter generation up to, but not including, output that represent an export of energy from that location. To determine the hours for which the Meter Data will be collected, the calculation will work sequentially backwards from the Trading Day under examination up to a maximum of forty-five (45) calendar days prior to the Trading Day, including only Business Days if the Trading Day is a Business Day, including only non-Business Days if the Trading Day is a non-Business Day, and excluding hours in which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) pursuant to a Bid at or above the net benefits test set forth in Section 30.6.3, or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services pursuant to a Bid at or above the net benefits test set forth in Section 30.6.3, except as discussed below. The calculation will have complete Meter Data for this purpose if and when it is able to collect Meter Data for its target number of hours the same as the Trading Hour, which target number is ten (10) hours if the Trading Day is a Business Day or four (4) hours if the Trading Day is a non-Business Day. If it is not possible to collect Meter Data for the target number of hours, the Meter Data will include a minimum of five (5) hours if the Trading Day is a Business Day or a minimum of four (4) hours if the Trading Day is a non-Business Day. If it is not possible to collect Meter Data for the minimum number of hours described above, the calculation will instead include Meter Data for the hours on which the Proxy Demand Resource was subject to an Outage or previously provided Demand Response Services (other than capacity awarded for AS or RUC) pursuant to a

Bid at or above the net benefits test set forth in Section 30.6.3, or the Reliability Demand Response Resource was subject to an Outage as described in the Business Practice Manual or previously provided Demand Response Services, and for which the amount of totalized load was highest during the hours when the Demand Response Services were provided in the forty-five (45) calendar days prior to the Trading Day.

- (b) The baseline amount of Energy provided by the behind-the-meter generation will be calculated on the simple hourly average of the collected Meter Data.
- (c) In calculating the Generator Output Baseline pursuant to 4.13.4.2(a), the Meter Data must be set to zero in any Settlement Interval in which the behind-the-meter generation is charging,
- (d) In any Settlement Interval where the behind-the-meter generation is exporting Energy (i.e., where the behind-the-meter generation Energy output exceeds its location Demand), the Meter Data will consist of the Energy output of the behind-the-meter generation up to, but not including, the output greater than its facility Demand that would represent an export of Energy from that location.